



# REPORT OF PERFORMANCE

TIC 1615-11

<b>OBJECT</b>	single-core power cable
<b>TYPE</b>	0,6/1 kV, 1x800 mm <sup>2</sup> CU/XLPE/TCUW/PVC
<b>MANUFACTURER</b>	National Cables Industry-Sharjah, U.A.E., Sharjah, U.A.E.
<b>CLIENT</b>	National Cables Industry-Sharjah, U.A.E., Sharjah, U.A.E.
<b>TESTED BY</b>	KEMA HIGH-VOLTAGE LABORATORY Arnhem, The Netherlands
<b>DATES OF TESTS</b>	29 September 2011 until 21 October 2011
<b>TEST PROGRAMME</b>	Type tests in accordance with IEC 60502-1 (2004) including Amendment 1 (2009).
<b>SUMMARY AND CONCLUSION</b>	The object passed the tests.

This Report of Performance applies only to the object tested. The responsibility for conformity of any object having the same designations with that tested rests with the Manufacturer.

This report consists of 28 pages in total.

© Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only".  
The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.

S.A.M. Verhoeven  
Director Testing, Inspections &  
Certification The Netherlands

Arnhem, 20 December 2011

## TABLE OF CONTENTS

TABLE OF CONTENTS .....	2
1 Identification of the test object.....	4
1.1 Description of the test object.....	4
1.2 List of documents .....	6
2 General information.....	7
2.1 The tests were witnessed by.....	7
2.2 The tests were carried out by.....	7
2.3 Subcontracting .....	7
2.4 Purpose of the test.....	7
2.5 Measurement uncertainty.....	7
2.6 Applicable standards.....	7
3 Conductor.....	8
3.1 Measurement of the resistance of the conductor.....	8
3.2 Measurement of the number of wires of the conductor.....	8
4 Electrical type tests .....	9
4.1 Measurement of insulation resistance at ambient temperature .....	9
4.2 Measurement of insulation resistance at max. conductor temperature in normal operation .....	10
4.3 Voltage test for 4 h.....	11
5 Non-electrical type tests.....	12
5.1 Measurement of thickness of insulation.....	12
5.2 Measurement of thickness of non-metallic sheaths .....	13
5.3 Tests for determining the mechanical properties of the insulation before and after ageing .....	14
5.4 Tests for determining the mechanical properties of non-metallic sheaths before and after ageing.....	15
5.5 Additional ageing test on pieces of completed cables .....	16
5.6 Loss of mass test on PVC sheath of type ST <sub>2</sub> .....	17
5.7 Pressure test at high temperature on PVC non-metallic sheath.....	18
5.8 Test on PVC insulation and sheaths and halogen free sheaths at low temperatures .....	19
5.9 Test for resistance of PVC sheath to cracking (heat shock test).....	20
5.10 Hot set test for XLPE insulation .....	21
5.11 Water absorption test on XLPE insulation .....	22
5.12 Fire tests.....	23
5.12.1 Flame spread test on single cables.....	23
5.13 Shrinkage test for XLPE insulation.....	24



6	Verification of cable construction .....	25
APPENDIX A	MEASUREMENT UNCERTAINTIES .....	26
APPENDIX B	MANUFACTURER'S DRAWING(S)/DATA SHEET .....	27

## 1 IDENTIFICATION OF THE TEST OBJECT

### 1.1 Description of the test object

Manufacturer	NATIONAL CABLES INDUSTRY-SHARJAH, U.A.E.
Type	0,6/1 kV, 1x800 mm <sup>2</sup> CU/XLPE/TCUW/PVC
Year of manufacture	2011
Test according to standard(s)	IEC 60502-1

Rated voltage, $U_0/U$ ( $U_m$ )	0,6/1 (1,2) kV
No. of cores	1
Marking on the cable	KAHRAMAA QATAR, 600/1000 VOLTS 1X800 MM <sup>2</sup> CU/XLPE/TCUW/PVC, IEC 60502, NATIONAL CABLES INDUSTRY, UAE, 2011

#### Conductor

- material	Copper
- cross-section	800 mm <sup>2</sup>
- approx. diameter/dimensions	33,7 mm
- type/shape of conductor	round compacted
- maximum conductor temperature in normal operation	90 °C

#### Insulation

- material	XLPE
- nominal thickness	2,6 mm
- material designation	known in KEMA's file
- material supplier	known in KEMA's file
- core identification	Black

#### Inner covering

- type	extruded
- material	PVC
- nominal thickness	1,4 mm
- material supplier	known in KEMA's file

Metallic armour

- |                                 |                       |
|---------------------------------|-----------------------|
| - material                      | Tinned Copper Wires   |
| - nominal diameter / dimensions | 48 x 2,5 mm           |
| - cross-sectional area          | 235,6 mm <sup>2</sup> |
| - material supplier             | known in KEMA's file  |

Oversheath

- |                           |                           |
|---------------------------|---------------------------|
| - material                | PVC, type ST <sub>2</sub> |
| - nominal thickness       | 2,5 mm                    |
| - outer diameter of cable | approx. 53 mm             |
| - material supplier       | known in KEMA's file      |
| - colour                  | black                     |

Fire retardant

Yes, as per (IEC 60332-1)

Manufacturing details (of cable sent to KEMA for testing)

- |   |                                       |
|---|---------------------------------------|
| - location of manufacturing   | Sharjah, U.A.E.                       |
| - factory identification of extrusion line                                  | NEXTROM                               |
| - manufacturer of the extrusion line  | NEXTROM                               |
| - identification of the production batch                                    | # 319084; identification no. 50738527 |
| - manufacturing length (where cable sample for testing has been taken from) | 1000 m                                |

## 1.2 List of documents

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following document.

KEMA has verified that this document adequately represents the object tested.

The following document is included in this report:

drawing no./ document no.	revision	date	title
0102Q26123R1	0	01.08.2011	cable drawing 1x800 mm <sup>2</sup> CU/XLPE/TCUW/PVC

## **2 GENERAL INFORMATION**

### **2.1 The tests were witnessed by**

The tests were not witnessed.

### **2.2 The tests were carried out by**

<b>Name</b>	<b>Company</b>
Mr B. Vos	DEKRA Certification B.V., Arnhem, the Netherlands

### **2.3 Subcontracting**

All tests were subcontracted to DEKRA Certification B.V.

### **2.4 Purpose of the test**

Purpose of the test was to verify whether the material complies with the specified requirements.

### **2.5 Measurement uncertainty**

A table with measurement uncertainties is enclosed in appendix A. Unless otherwise indicated in the report, the measurement uncertainties of the results presented are as indicated in this table.

### **2.6 Applicable standards**

When reference is made to a standard and the date of issue is not stated, this applies to the latest issue, including amendments, which have been officially published prior to the date of the tests.

### 3 CONDUCTOR

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 5

Test date 29 September 2011

#### 3.1 Measurement of the resistance of the conductor

item	unit	requirement	measured/determined
- resistance	$\Omega/\text{km}$	$\leq 0,0221$	0,0221

#### Result

The object passed the test.

#### 3.2 Measurement of the number of wires of the conductor

item	unit	requirement	measured/determined
- number of wires	-	$\geq 53$	61

#### Result

The object passed the test.



## 4 ELECTRICAL TYPE TESTS

### 4.1 Measurement of insulation resistance at ambient temperature

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 17.1  
Test date 4 October 2011

item	unit	requirement	measured/determined
<b>volume resistivity, <math>\rho</math></b> at 20 °C	$\Omega.cm$	–	$9 \times 10^{16}$
<b>insulation resistance constant, <math>K_i</math></b> at 20 °C	$M\Omega.km$	–	318503

#### Result

The test results are for information only.

#### 4.2 Measurement of insulation resistance at max. conductor temperature in normal operation

##### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 17.2

Test date 6 October 2011

item	unit	requirement	measured/determined
<b>volume resistivity, <math>\rho</math></b> at 90 °C	$\Omega$ .cm	$\geq 10^{12}$	$1,2 \times 10^{16}$
<b>insulation resistance constant, <math>K_i</math></b> at 90 °C	M $\Omega$ .km	$\geq 3,67$	45439

##### Result

The object passed the test.

### 4.3 Voltage test for 4 h

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 17.3

Test date 29 September 2011

#### Environmental conditions

Temperature  $20 \pm 2$  °C

applied voltage (kV)	frequency (Hz)	duration (h)	measured/determined
2,4	50	4	no breakdown

#### Requirement

No breakdown of the insulation shall occur.

#### Result

The object passed the test.

## 5 NON-ELECTRICAL TYPE TESTS

### 5.1 Measurement of thickness of insulation

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.1

Test date 5 October 2011

insulation thickness	unit	requirement	specified	measured/determined
- nominal	mm	$\geq 2,6$	2,6	-
- average	mm	-	-	3,3
- minimum ( $t_m$ )	mm	$\geq 2,24$	-	3,11

#### Result

The object passed the test.

## 5.2 Measurement of thickness of non-metallic sheaths

### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.2

Test date 5 October 2011

### Oversheath

thickness	unit	requirement	specified	measured/determined
- nominal	mm	$\geq 1,4$	2,5	-
- average	mm	-	-	3,2
- minimum ( $t_{min}$ )	mm	$\geq 1,8$	1,8	2,96

### Inner sheath

thickness	unit	requirement	specified	measured/determined
- nominal	mm	-	1,4	-
- average	mm	-	-	1,7
- minimum ( $t_{min}$ )	mm	-	0,92	1,55

### Result

The object passed the test.

### 5.3 Tests for determining the mechanical properties of the insulation before and after ageing

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.3

Test period 5 October 2011 until 13 October 2011

#### Characteristic test data

Temperature during ageing 135 ±3 °C

Duration 7 days

item	unit	requirement	measured/determined
<b>without ageing</b>			
- tensile strength	N/mm <sup>2</sup>	≥ 12,5	26,4
- elongation	%	≥ 200	624
<b>after ageing</b>			
- tensile strength	N/mm <sup>2</sup>	-	27,4
- variation with samples without ageing	%	± 25 max.	4
- elongation	%	-	598
- variation with samples without ageing	%	± 25 max.	-4

#### Result

The object passed the test.

## 5.4 Tests for determining the mechanical properties of non-metallic sheaths before and after ageing

### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.4

Test period 5 October 2011 until 13 October 2011

### Characteristic test data (oversheath)

Temperature during ageing 100 ± 2 °C

Duration 7 days

### Oversheath

item	unit	requirement	measured/determined
<b>without ageing</b>			
- tensile strength	N/mm <sup>2</sup>	≥ 12,5	19,2
- elongation	%	≥ 150	222
<b>after ageing</b>			
- tensile strength	N/mm <sup>2</sup>	≥ 12,5	18,3
- variation with samples without ageing	%	± 25 max.	-5
- elongation	%	≥ 150	213
- variation with samples without ageing	%	± 25 max.	-4

### Result

The object passed the test.

## 5.5 Additional ageing test on pieces of completed cables

### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.5  
 Test period 5 October 2011 until 13 October 2011

### Characteristic test data

Temperature during ageing 100 ± 2 °C  
 Duration 7 days

### Insulation

item	unit	requirement	measured/determined
- tensile strength	N/mm <sup>2</sup>	-	25,2
- variation with samples without ageing	%	± 25 max.	-5
- elongation	%	-	606
- variation with samples without ageing	%	± 25 max.	-3

### Oversheath

item	unit	requirement	measured/determined
- tensile strength	N/mm <sup>2</sup>	-	18,6
- variation with samples without ageing	%	± 25 max.	-3
- elongation	%	-	216
- variation with samples without ageing	%	± 25 max.	-3

### Result

The object passed the test.



## 5.6 Loss of mass test on PVC sheath of type ST<sub>2</sub>

### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.6

Test period 4 October 2011 until 13 October 2011

### Characteristic test data

Temperature during ageing 100 ± 2 °C

Duration 7 days

### Oversheath

item	unit	requirement	measured/determined
- loss of mass	mg/cm <sup>2</sup>	≤ 1,5	0,3

### Result

The object passed the test.

### 5.7 Pressure test at high temperature on PVC non-metallic sheath

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.7  
Test date 7 October 2011

#### Characteristic test data

Temperature during ageing 90 ± 2 °C  
Duration 6 h  
Load 18,8 N

#### Oversheath

item	unit	requirement	measured/determined
- depth of indentation	%	≤ 50	27

#### Result

The object passed the test.

### 5.8 Test on PVC insulation and sheaths and halogen free sheaths at low temperatures

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.8

Test date 27 September 2011

#### Characteristic test data

Temperature  $-15 \pm 2$  °C

Mass of hammer 1250 g

#### Oversheath

item	unit	requirement	measured/determined
- cold elongation	%	$\geq 20$	130
- cold impact test	-	no cracks	no cracks

#### Result

The object passed the test.

### 5.9 Test for resistance of PVC sheath to cracking (heat shock test)

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.9

Test date 7 October 2011

#### Characteristic test data (oversheath)

Temperature 150 ± 3 °C

Duration 1 h

Diameter of mandrel 8 mm

Number of turns 4

#### Oversheath

item	unit	requirement	measured/determined
- soundness	-	no cracks	no cracks

#### Result

The object passed the test.

### 5.10 Hot set test for XLPE insulation

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.11

Test date 7 October 2011

#### Characteristic test data

Temperature 200 ± 3 °C

Time under load 15 min

Mechanical stress 20 N/cm<sup>2</sup>

item	unit	requirement	measured/determined
- elongation under load	%	≤ 175	95
- permanent elongation	%	≤ 15	10

#### Result

The object passed the test.

### 5.11 Water absorption test on XLPE insulation

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.13

Test period 22 September 2011 until 11 October 2011

#### Characteristic test data

Temperature  $85 \pm 2$  °C

Duration 14 days

item	unit	requirement	measured/determined
- variation of mass	mg/cm <sup>2</sup>	≤ 1	0,1

#### Result

The object passed the test.

## 5.12 Fire tests

### 5.12.1 Flame spread test on single cables

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.14.1 and IEC 60332-1  
Test date 21 October 2011

#### Characteristic test data

Duration 240 s

item	unit	requirement	measured/determined
- length free of charring	mm	> 50	360
- downward limit charred surface	mm	< 540	500

#### Result

The object passed the test.

### 5.13 Shrinkage test for XLPE insulation

#### Standard and date

Standard IEC 60502-1 (2004) +A1 (2009), clause 18.16

Test date 26 September 2011

#### Characteristic test data

Temperature 130 ±3 °C

Duration 1 h

item	unit	requirement	measured/determined
- shrinkage	%	≤ 4	2

#### Result

The object passed the test.



## 6 VERIFICATION OF CABLE CONSTRUCTION

Verification of cable construction was carried out in accordance with clauses 5-13 of IEC 60502-1. The results are presented below.

	observed/determined
construction	<ul style="list-style-type: none"> <li>- round compacted copper conductor</li> <li>- construction : 1-6-12-18-24 wires <math>\varnothing</math> 4,1 mm</li> <li>- XLPE insulation</li> <li>- inner sheath (extruded PVC)</li> <li>- water blocking tape</li> <li>- armour of tinned copper wires; 50 wires <math>\varnothing</math> 2,5 mm</li> <li>- water blocking tape</li> <li>- oversheath (extruded PVC)</li> </ul>
outer diameter of the cable, average	58 mm (approx.)
outer diameter of the cores, average	34 mm (approx.)

### Result

No deviations from the specified requirements are found.

## APPENDIX A MEASUREMENT UNCERTAINTIES

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

measurement	measurement uncertainty
tensile strenght test	1%
measurement of dimensions	5 $\mu\text{m}$
measurement loss of mass	0,11 mg : 8,0 gr
measurement of conductor resistance	0,03% of measured value
measurement at low temperature	0,1 $^{\circ}\text{C}$
measurment in heatingcabinets	0,1 $^{\circ}\text{C}$
voltage test	$2 \cdot 10^{-3} \cdot U + 20\text{V}$
	$2 \cdot 10^{-3} \cdot I + 0,2\%$

## APPENDIX B MANUFACTURER'S DRAWING(S)/DATA SHEET

2 pages (including this page)

drawing no./ document no.	revision	date	title
0102Q26123R1	0	01.08.2011	cable drawing 1x800 mm <sup>2</sup> CU/XLPE/TCUW/PVC

Drawing No.: 0102Q26123R1 Rev. 0  
Dated: 01.08.2011

TECHNICAL & QC  
DEPARTMENT

الوطنية لصناعة الكابلات  
NATIONAL CABLES INDUSTRY NCI


**CABLE DRAWING**

Cable size : 1x800 MM <sup>2</sup>	Rated Voltage : 0.6/1 (1.2) kV	Cable code: 0102Q26123R1
Cable Type : CU/XLPE/TCUW/PVC	Ref. Standards : IEC 60502-1 & KAHRAMAA Spec no: ED-03-040	: Version#5 Rev-0/2010

**DIMENSION DATA:**

S.NO	DESCRIPTION	UNIT	OFFER DETAILS
1	<b>CONDUCTOR:</b> Material Form of stranding Approximate diameter D.C. Resistance at 20°C	mm Ω/km	Copper Round compacted 34.2 0.0221
2	<b>INSULATION:</b> Material Nominal thickness Approximate diameter Colors	mm mm	Extruded XLPE 2.6 39.4 Red or Black
3	<b>INNER SHEATH:</b> Material Nominal thickness Approximate diameter	mm mm	Extruded PVC 1.4 42.2
4	<b>WATER BARRIER TAPES</b> Material Nominal thickness Approximate diameter	mm mm	Non conductive water swellable tape 0.15 42.6
5	<b>ARMOUR:</b> Material Wire diameter Approximate diameter	mm mm	Tinned copper wires 2.5 47.6
6	<b>WATER BARRIER TAPES</b> Material Nominal thickness Approximate diameter	mm mm	Non conductive water swellable tape 0.15 48
7	<b>OUTER SHEATH:</b> Material Nominal thickness Approximate overall diameter Color	mm mm	Extruded PVC 2.5 53.0 Black

**DRAWING:**



Note: Water barrier tapes shall be applied under and over armour to prevent movement of water in transverse and longitudinal direction


**CABLE MARKING:**


Embossing on the outer sheath in max 50 cm spacing in one line:  
KAHRAMAA QATAR, 600/1000 VOLTS, 1x800MM<sup>2</sup>, CU/XLPE/TCUW/PVC, IEC 60502  
NATIONAL CABLES INDUSTRY, U.A.E., 2011


**PACKAGING:**

Approximate weight of complete cable	: 10650 kg/km
Nominal cutting length	: 300 M ± 5%
Drum type	: Steel or Wooden
Drum dimensions (Approx.):	
• Outer diameter	: 1850 mm
• Outer width	: 1100 mm

All diameters and weights are approximate.

Prepared by: 

Checked by: 

Approved by: 



	P.O.Box: 27472, Sharjah, U.A.E. ☎ Tel: 06-5311888 (8 Lines) ☎ Fax: 06-5311577- CR: 35305 / IR: 50687	
e-mail: n_c_i@emirates.net.ae website: www.nci.ae		
		

FORM # TE01/F06 Rev. 02