



# Test Report

## No. TR-009-2019

For

### Type Testing of $3 \times 500/35 \text{mm}^2$ , AL/XLPE/LLDPE 15kV Medium Voltage Power Cable

Test carried out at

*The High Voltage Laboratory*

Ramadan, 1440 H  
May, 2019 G



Total No. of Pages including Appendix: 18



## TEST REPORT No. TR-009-2019

|                          |   |
|--------------------------|---|
| OBJECT                   | Medium Voltage Electric Power Cable           |
| TYPE                     | 3 × 500/35mm <sup>2</sup> AL/XLPE/LLDPE, 15kV |
| MANUFACTURER             | NATIONAL CABLES INDUSTRIES, Sharjah - UAE     |
| TRADE NAME               | NATIONAL CABLES INDUSTRIES                    |
| DATE OF TEST             | May, 2019                                     |
| TEST REFERENCE STANDARDS | IEC 60502-2:2014 & 11-SDMS-04 Rev. 0:2018     |

**SUMMARY AND CONCLUSION** All tests passed.

*This type test report applies only to the object tested. The responsibility for conformity of any production having the same designation as the tested sample rests with the manufacturer.*

**Prof. Dr. Abdulrehman A. Al-Arainy**  
Manager  
High Voltage Laboratory,  
King Saud University,  
Riyadh, KSA







## TABLE OF CONTENTS

|   |    |
|---|----|
| 1. IDENTIFICATION OF THE TEST OBJECT .....  | 4  |
| 2. GENERAL INFORMATION .....  | 5  |
| 3. ROUTINE TESTS.....   | 6  |
| 3.1 MEASUREMENT OF THE RESISTANCE OF ALUMINUM CONDUCTORS .....  | 6  |
| 4. MEASUREMENTS ON CONDUCTOR .....  | 6  |
| 5. ELECTRICAL TYPE TESTS.....   | 7  |
| 5.1 BENDING TEST .....  | 7  |
| 5.2 PARTIAL DISCHARGE TEST AFTER BENDING.....   | 7  |
| 5.3 TAN DELTA MEASUREMENT.....  | 7  |
| 5.4 HEATING CYCLE TEST .....  | 8  |
| 5.5 PARTIAL DISCHARGE TEST AFTER HEATING CYCLE .....  | 8  |
| 5.6 IMPULSE TEST FOLLOWED BY AC VOLTAGE TEST.....   | 8  |
| 5.7 AC VOLTAGE TEST FOR 4 HRS. ....   | 11 |
| 5.8 RESISTIVITY OF SEMI-CONDUCTING SCREENS .....  | 11 |
| 6. NON-ELECTRICAL TYPE TESTS.....   | 12 |
| 6.1 MEASUREMENT OF THICKNESS OF INSULATION .....  | 12 |
| 6.2 MEASUREMENT OF THICKNESS OF NON-METALLIC SHEATHING.....   | 12 |
| 6.3 TESTS FOR DETERMINING THE MECHANICAL PROPERTIES OF THE INSULATION BEFORE AND AFTER AGEING.....      | 13 |
| 6.4 TESTS FOR DETERMINING THE MECHANICAL PROPERTIES OF THE NON-METALLIC SHEATHS BEFORE AND AFTER AGEING | 13 |
| 6.5 ADDITIONAL AGEING TEST ON PIECES OF COMPLETED CABLES .....  | 14 |
| 6.6 PRESSURE TEST AT HIGH TEMPERATURE ON NON-METALLIC SHEATHS .....                                     | 15 |
| 6.7 HOT SET TEST FOR XLPE INSULATION .....  | 15 |
| 6.8 WATER ABSORPTION TEST ON INSULATION .....   | 15 |
| 6.9 SHRINKAGE TEST FOR XLPE INSULATION .....  | 16 |
| 6.10 SHRINKAGE TEST FOR LLDPE SHEATH .....  | 16 |
| 6.11 STRIPPABILITY TEST FOR INSULATION SCREEN BEFORE AND AFTER AGEING .....                             | 16 |
| 6.12 CARBON BLACK CONTENTS (OUTER LLDPE SHEATH) .....   | 17 |
| 7. VERIFICATION OF CABLE CONSTRUCTION .....   | 17 |
| 8. APPENDIX A. MANUFACTURER'S DRAWING / DATA SHEET .....  | 18 |





## 1. IDENTIFICATION OF THE TEST OBJECT

### 1.1 Description of the test object

|                     |   |
|---------------------|---|
| OBJECT              | Medium Voltage Cable                              |
| KSU LAB ID #        | HVS – 009/2019                                    |
| MANUFACTURER        | NATIONAL CABLES INDUSTRIES<br>Sharjah, UAE        |
| TYPE                | 15kV , 3 × 500/35 mm <sup>2</sup> , AL/XLPE/LLDPE |
| YEAR OF MANUFACTURE | 2019  |
| SAMPLING PROCEDURE  | 22 meter cable sample cut from the drum           |
| RATED VOLTAGE       | 15 kV   |
| NO. OF CORES        | 3   |

### Manufacturer specified values

|                               |                                    |                 |
|-------------------------------|------------------------------------|-----------------|
| <b>1. Conductor</b>           |                                    |                 |
| Material                      | Aluminum                           |                 |
| Size                          | 500                                | mm <sup>2</sup> |
| Shape                         | RMC                                |                 |
| Minimum no. of wires          | 61                                 |                 |
| Conductor diameter            | 26.7 (Approximate)                 | mm              |
| Max. DC Resistance at 20 °C   | 0.0605                             | Ω / km          |
| <b>2. Conductor Screen *</b>  |                                    |                 |
| Material                      | Extruded Semi-conducting material  |                 |
| Type                          | Bonded Type                        |                 |
| Thickness :                   |                                    |                 |
| min                           | 0.51                               | mm              |
| <b>3. Insulation</b>          |                                    |                 |
| Material                      | Cross-linked Polyethylene [ XLPE ] |                 |
| Thickness :                   |                                    |                 |
| - Nominal                     | 4.5                                | mm              |
| Diameter over insulation      | 37.3 (Approximate)                 | mm              |
| <b>4. Insulation Screen *</b> |                                    |                 |
| Material                      | Extruded Semi-conducting material  |                 |
| Type                          | Cold Strippable Type               |                 |
| Thickness :                   |                                    |                 |
| - Maximum                     | 1.91                               | mm              |
| - Minimum                     | 1.02                               | mm              |
| <b>5. Metallic Screen</b>     |                                    |                 |
| Material                      | Copper Wires + Copper Tape         |                 |
| No. of wires                  | 27 / Core                          |                 |
| Wire diameter                 | 0.7                                | mm              |
| No. of open helix tapes       | 1 / Core                           |                 |
| Width x Thickness             | 15 x 0.1                           | mm              |

#### 6. Assembly

|                             |                                 |    |
|-----------------------------|---------------------------------|----|
| Material                    | Polypropylene [ Filler + Tape ] |    |
| Diameter under binding tape | 90.6 (Approximate)              | mm |
| Binding tape material       | Mylar tape                      |    |
| - Thickness                 | 0.075                           | mm |

#### 7. Outer Sheath

|                             |                  |    |
|-----------------------------|------------------|----|
| Material                    | LLDPE TYPE ST-7  |    |
| Color                       | Black            |    |
| Thickness :                 |                  |    |
| - Nominal                   | 3.9              | mm |
| Diameter under outer sheath | 90.9             | mm |
| Overall cable diameter      | 99 (Approximate) | mm |

#### 1.2 List of documents

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following document.

The following document is included in this report:

| SPECIFICATION | REVISION | DATE      | TITLE  |
|---------------|----------|-----------|--|
| 11-SDMS-04    | Rev. 0   | July 2018 | Design data sheet for three core AL/XLPE/LLDPE, 15kV power cable<br>Size: 3 x 500/35 mm <sup>2</sup> |

## 2. GENERAL INFORMATION

2.1 The tests were carried out by : following members of HV laboratory of King Saud University

- Prof. Yasin Khan
- Eng. Nissar R. Wani





## 2.2 Purpose of the test

Purpose of the test was to verify whether the material complies with the specified requirements.

## 2.3 Applicable standards

### IEC 60502-2: 2014

When reference is made to a standard and the date of issue is not stated, this applies to the latest issue, including amendments, which have been officially published prior to the date of the tests.

## 3 ROUTINE TESTS

### 3.1 Measurement of the resistance of Aluminum conductors

| Item       | Unit               | Requirement   | Measured/Determined |        |        | Result |
|------------|--------------------|---------------|---------------------|--------|--------|--------|
|            |                    |               | Red                 | Yellow | Blue   |        |
| Resistance | $\Omega/\text{km}$ | $\leq 0.0605$ | 0.0600              | 0.0600 | 0.0600 | pass   |

## 4 MEASUREMENTS ON CONDUCTOR

### Standard

Standard IEC 60228 & IEC 60502-2 (2014), Clause 17.4

### 4.1 Measurement on Aluminum Conductors

| Item               | Unit | Requirement    | Measured/Determined |        |       | Result |
|--------------------|------|----------------|---------------------|--------|-------|--------|
|                    |      |                | Red                 | Yellow | Blue  |        |
| Number of wires    | No's | $\geq 53$      | 61                  | 61     | 61    | Pass   |
| Conductor diameter | mm   | 26.7 (Approx.) | 26.99               | 27.12  | 27.10 | Pass   |

### 4.2 Measurement of the dimension of metallic screen

| Item   | Unit     | Requirement                               | Measured/Determined |           |           | Result |
|--|----------|---|---------------------|-----------|-----------|--------|
|  |          |   | Red                 | Yellow    | Blue      |        |
| Plain copper wire Screen Dimension                       | No. x mm | 27 / Core X 0.7                           | 27 x 0.71           | 27 x 0.71 | 27 x 0.71 | Pass   |
| Open helix copper tape over copper wire screen dimension | mm       | No x Width x Thickness<br>(1 x 15 x 0.10) | 1 x 15 x 0.10       |           |           |        |

## 5 ELECTRICAL TYPE TESTS

### 5.1 Bending test

#### Standard

Standard IEC 60502-2 (2014), clause 18.2.4

Sample length 17m

| Description       | Size            | Voltage | D     | d  | Calculated test cylinder diameter $15(d + D) + 5\%$ (Maximum) | Actual measured Barrel Diameter |
|-------------------|-----------------|---------|-------|----|---|---------------------------------|
| Unit              | mm <sup>2</sup> | kV      | mm    | mm | mm  | mm                              |
| Al / XLPE / LLDPE | 3 x 500         | 15      | 96.77 | 27 | 1949  | 1800                            |

\* Carried out at Riyadh Cables test lab

#### Result

The test was done in a satisfactory manner

### 5.2 Partial Discharge Test after Bending

#### Standard

Standard IEC 60502-2 (2014), clause 18.2.5

| Item                   | Required test voltage ( $1.73 U_0$ ) | Requirement | Measured/Determined |        |        | Result |
|------------------------|--------------------------------------|-------------|---------------------|--------|--------|--------|
|                        |                                      |             | Red                 | Yellow | Blue   |        |
| Partial Discharge Test | 15 kV                                | $\leq 5$ pC | 1.2 pC              | 1.2 pC | 1.2 pC | Pass   |

### 5.3 Tan Delta measurement

#### Standard

Standard IEC 60502-2 (2014), clause 18.2.6

Conductor temperature during the test (95 - 100) °C

| Item                  | Applied voltage | Requirement              | Measured/Determined |                    |                    | Result |
|-----------------------|-----------------|--------------------------|---------------------|--------------------|--------------------|--------|
|                       |                 |                          | Red                 | Yellow             | Blue               |        |
| Tan Delta measurement | $\geq 2$ kV     | $\leq 40 \times 10^{-4}$ | $2 \times 10^{-4}$  | $1 \times 10^{-4}$ | $1 \times 10^{-4}$ | Pass   |



#### 5.4 Heating Cycle Test

##### Standard

Standard IEC 60502-2 (2014), clause 18.2.7

Duration (8hrs/cycle)

| Heating Time/ Cycle | Heating Temp.( ° C ) | Maintaining Temp. ( at 96 ° C ) for | Cooling Time/ Cycle | Total Cycle Time ( Heating & Cooling ) | Total No. of Cycles |
|---------------------|----------------------|-------------------------------------|---------------------|--|---------------------|
| 5 Hours             | (95 - 100) °C        | 2 Hours                             | 3 Hours             | 8 Hours                                | 20                  |

##### Result

The test was done with satisfactory results

#### 5.5 Partial Discharge Test after Heating Cycle

##### Standard

Standard IEC 60502-2 (2014), clause 18.2.5

| Item                   | Required test voltage ( 1.73 U <sub>0</sub> ) | Requirement | Measured/Determined |        |        | Result |
|------------------------|---|-------------|---------------------|--------|--------|--------|
|                        |   |             | Red                 | Yellow | Blue   |        |
| Partial Discharge Test | 15 kV   | ≤ 5 pC      | 3.3 pC              | 3.2 pC | 3.3 pC | Pass   |

#### 5.6 Impulse test followed by AC voltage test

##### 5.6.1 Impulse test

##### Standard

Standard IEC 60502-2 (2014), clause 18.2.8

##### Characteristic


Conductor temperature during the test (95 - 100) °C

No. of voltage impulses 10 Positive & 10 Negative


| Item         | Sample rated voltage (kV) | Test voltage Peak (kV) | Requirement  | Measured/Determined |              |              | Result |
|--------------|---------------------------|------------------------|--------------|---------------------|--------------|--------------|--------|
|              |                           |                        |              | Red                 | Yellow       | Blue         |        |
| Impulse test | 15                        | 95                     | No Breakdown | No Breakdown        | No Breakdown | No Breakdown | Pass   |

Impulse test waveforms are shown next.






| CH              | No | Value   |
|-----------------|----|---------|
| CH1             | No | 13471   |
| U <sub>pp</sub> |    | 95.49kV |
| CH2             | No | 13472   |
| U <sub>pp</sub> |    | 95.43kV |
| CH3             | No | 13473   |
| U <sub>pp</sub> |    | 95.5kV  |
| CH4             | No | 13474   |
| U <sub>pp</sub> |    | 95.5kV  |
| CH5             | No | 13475   |
| U <sub>pp</sub> |    | 95.54kV |
| CH6             | No | 13476   |
| U <sub>pp</sub> |    | 95.5kV  |
| CH7             | No | 13477   |
| U <sub>pp</sub> |    | 95.48kV |
| CH8             | No | 13478   |
| U <sub>pp</sub> |    | 95.52kV |
| CH9             | No | 13479   |
| U <sub>pp</sub> |    | 95.51kV |
| CH10            | No | 13480   |
| U <sub>pp</sub> |    | 95.45kV |




| CH              | No | Value    |
|-----------------|----|----------|
| CH1             | No | 13461    |
| U <sub>pp</sub> |    | -95.79kV |
| CH2             | No | 13462    |
| U <sub>pp</sub> |    | -95.88kV |
| CH3             | No | 13463    |
| U <sub>pp</sub> |    | -95.82kV |
| CH4             | No | 13464    |
| U <sub>pp</sub> |    | -95.84kV |
| CH5             | No | 13465    |
| U <sub>pp</sub> |    | -95.83kV |
| CH6             | No | 13466    |
| U <sub>pp</sub> |    | -95.84kV |
| CH7             | No | 13467    |
| U <sub>pp</sub> |    | -95.77kV |
| CH8             | No | 13468    |
| U <sub>pp</sub> |    | -95.75kV |
| CH9             | No | 13469    |
| U <sub>pp</sub> |    | -95.82kV |
| CH10            | No | 13470    |
| U <sub>pp</sub> |    | -95.82kV |

PHASE – RED



| CH              | No | Value   |
|-----------------|----|---------|
| CH1             | No | 13471   |
| U <sub>pp</sub> |    | 95.49kV |
| CH2             | No | 13472   |
| U <sub>pp</sub> |    | 95.43kV |
| CH3             | No | 13473   |
| U <sub>pp</sub> |    | 95.5kV  |
| CH4             | No | 13474   |
| U <sub>pp</sub> |    | 95.5kV  |
| CH5             | No | 13475   |
| U <sub>pp</sub> |    | 95.54kV |
| CH6             | No | 13476   |
| U <sub>pp</sub> |    | 95.5kV  |
| CH7             | No | 13477   |
| U <sub>pp</sub> |    | 95.48kV |
| CH8             | No | 13478   |
| U <sub>pp</sub> |    | 95.52kV |
| CH9             | No | 13479   |
| U <sub>pp</sub> |    | 95.51kV |
| CH10            | No | 13480   |
| U <sub>pp</sub> |    | 95.45kV |




| CH              | No | Value    |
|-----------------|----|----------|
| CH1             | No | 13481    |
| U <sub>pp</sub> |    | -95.83kV |
| CH2             | No | 13482    |
| U <sub>pp</sub> |    | -95.65kV |
| CH3             | No | 13483    |
| U <sub>pp</sub> |    | -95.67kV |
| CH4             | No | 13484    |
| U <sub>pp</sub> |    | -95.69kV |
| CH5             | No | 13485    |
| U <sub>pp</sub> |    | -95.67kV |
| CH6             | No | 13486    |
| U <sub>pp</sub> |    | -95.84kV |
| CH7             | No | 13487    |
| U <sub>pp</sub> |    | -95.85kV |
| CH8             | No | 13488    |
| U <sub>pp</sub> |    | -95.81kV |
| CH9             | No | 13489    |
| U <sub>pp</sub> |    | -95.83kV |
| CH10            | No | 13490    |
| U <sub>pp</sub> |    | -95.81kV |

PHASE- YELLOW

*Handwritten signature*





PHASE- BLUE

5.6.2 AC Voltage test

Standard

Standard IEC 60502-2 (2014), clause 16.4

Characteristic

Temperature during Test 27°C  
Duration of voltage 15 min

| Item         | Required test voltage<br>3.5U <sub>0</sub> (kV) | Applied<br>test voltage<br>(kV) | Duration<br>min | Measured/Determined      | Result |
|--------------|---|---------------------------------|-----------------|--------------------------|--------|
| Voltage test | 31  | 31                              | 15              | No Breakdown in any core | Pass   |



### 5.7 AC Voltage test for 4 hrs.


#### Standard

Standard IEC 60502-2 (2014), clause 18.2.9

#### Environmental conditions

Temperature of test object 27 °C

| Item         | Required test voltage<br>4U <sub>0</sub> (kV) | Applied test voltage<br>(kV) | Duration<br>(hrs) | Determined               | Result |
|--------------|---|------------------------------|-------------------|--------------------------|--------|
| Voltage test | 35  | 35                           | 4                 | No Breakdown in any core | Pass   |



### 5.8 Resistivity of Semi-Conducting Screens

#### Standard

Standard IEC 60502-2 (2014), clause 18.2.10

#### Environmental conditions

Temperature of test object 90 ± 2 °C

| Item              | Unit | Requirement | Measured/Determined |        |       | Result |
|-------------------|------|-------------|---------------------|--------|-------|--------|
|                   |      |             | Red                 | Yellow | Blue  |        |
| Conductor Screen  |      |             |                     |        |       |        |
| - Before ageing   | Ω.m  | ≤ 1000      | 7.77                | 18.98  | 28.79 | Pass   |
| - After ageing    | Ω.m  | ≤ 1000      | 1.09                | 12.04  | 28.63 |        |
| Insulation Screen |      |             |                     |        |       |        |
| - Before ageing   | Ω.m  | ≤ 500       | 3.17                | 5.42   | 8.41  | Pass   |
| - After ageing    | Ω.m  | ≤ 500       | 1.38                | 2.19   | 2.72  |        |

## 6 NON-ELECTRICAL TYPE TESTS

### 6.1 Measurement of thickness of insulation

#### Standard

Standard IEC 60502-2 (2014), clause 19.2

#### Results of the measurement of thickness of XLPE insulation

| thickness                          | Unit | Requirement specified | Measured/Determined |        |      | Result |
|------------------------------------|------|-----------------------|---------------------|--------|------|--------|
|                                    |      |                       | Red                 | Yellow | Blue |        |
| Nominal ( $T_{nom.}$ )             | mm   | 4.50                  | 4.67                | 4.63   | 4.60 | Pass   |
| Minimum ( $T_{min.}$ )             | mm   | $\geq 3.95$           | 4.61                | 4.46   | 4.45 |        |
| $(T_{max.} - T_{min.}) / T_{max.}$ | mm   | $\leq 0.15$           | 0.03                | 0.05   | 0.06 |        |

#### Results of the measurement of thickness of conductor screen

| thickness | Unit | Requirement specified | Measured/Determined |        |      | Result |
|-----------|------|-----------------------|---------------------|--------|------|--------|
|           |      |                       | Red                 | Yellow | Blue |        |
| Minimum   | mm   | $\geq 0.51$           | 0.88                | 0.81   | 0.85 | Pass   |

#### Results of the measurement of thickness of insulation screen

| thickness | Unit | Requirement specified | Measured/Determined |        |      | Result |
|-----------|------|-----------------------|---------------------|--------|------|--------|
|           |      |                       | Red                 | Yellow | Blue |        |
| Minimum   | mm   | $\geq 1.02$           | 1.14                | 1.10   | 1.12 | Pass   |
| Maximum   | mm   | $\leq 1.91$           | 1.26                | 1.32   | 1.31 |        |

### 6.2 Measurement of thickness of non-metallic sheathing

#### Standard

Standard IEC 60502-2 (2014), clause 19.3

#### Outer Sheath

| Thickness Requirement |             | Unit | Measured/Determined |         | Result |
|-----------------------|-------------|------|---------------------|---------|--------|
| nominal               | minimum     |      | nominal             | minimum |        |
| 3.9                   | $\geq 3.12$ | mm   | 3.9                 | 3.21    | Pass   |



### 6.3 Tests for determining the mechanical properties of the insulation before and after ageing

#### Standard

Standard IEC 60502-2(2014), clause 19.5

#### Characteristic

Temperature during ageing 135°C ± 3K  
Duration 7 days

#### Mechanical properties before ageing

| Item                           | Unit              | Requirement | Measured/Determined |        |        | Result |
|--------------------------------|-------------------|-------------|---------------------|--------|--------|--------|
|                                |                   |             | Red                 | Yellow | Blue   |        |
| Tensile strength before ageing | N/mm <sup>2</sup> | ≥ 12.5      | 22.50               | 24.46  | 24.37  | Pass   |
| Elongation before ageing       | %                 | ≥200        | 638.40              | 741.95 | 567.00 |        |

#### Mechanical properties after ageing

| Item                                  | Unit              | Requirement | Measured/Determined |         |         | Result |
|---------------------------------------|-------------------|-------------|---------------------|---------|---------|--------|
|                                       |                   |             | Red                 | Yellow  | Blue    |        |
| Tensile strength                      | N/mm <sup>2</sup> | -----       | 23.22               | 26.42   | 20.60   | Pass   |
| Variation with samples without ageing | %                 | ± 25 max.   | +3.2                | +8.01   | - 15.45 |        |
| Elongation                            | %                 | -----       | 643.65              | 665.25  | 523.45  | Pass   |
| Variation with samples without ageing | %                 | ± 25 max.   | +0.82               | - 10.34 | - 7.68  |        |

### 6.4 Tests for determining the mechanical properties of the non-metallic sheaths before and after ageing

#### Standard

Standard IEC 60502-2(2014), clause 19.6

#### Characteristic (Outer Sheath)

Material LLDPE – TYPE ST-7  
Temperature during ageing 110 °C ± 2K  
Duration 10 days

#### Mechanical properties before ageing

| Item                            | Unit              | Requirement | Measured/Determined | Result |
|---------------------------------|-------------------|-------------|---------------------|--------|
| Tensile strength Without ageing | N/mm <sup>2</sup> | ≥ 12.5      | 19.79               | Pass   |
| Elongation Without ageing       | %                 | ≥ 300       | 859.60              |        |



### Mechanical properties after ageing

| Item                                  | Unit              | Requirement | Measured/Determined | Result |
|---------------------------------------|-------------------|-------------|---------------------|--------|
| Tensile strength                      | N/mm <sup>2</sup> | -----       | 18.11               | Pass   |
| Variation with samples without ageing | %                 | -----       | -8.48               |        |
| Elongation                            | %                 | ≥ 300       | 950.40              | Pass   |
| Variation with samples without ageing | %                 | -----       | +10.56              |        |

### 6.5 Additional ageing test on pieces of Completed cables

#### Standard

Standard IEC 60502-2(2014), clause 19.7

#### Characteristic test data

Temperature during ageing 100 °C ± 2K

Duration 7 days

#### Insulation

| Item                                  | Unit              | Requirement | Measured/Determined |         |        | Result |
|---------------------------------------|-------------------|-------------|---------------------|---------|--------|--------|
|                                       |                   |             | Red                 | Yellow  | Blue   |        |
| tensile strength                      | N/mm <sup>2</sup> | -----       | 23.56               | 22.43   | 24.74  | Pass   |
| variation with samples without ageing | %                 | ± 25 max.   | + 4.71              | - 8.29  | +1.52  |        |
| elongation                            | %                 | -----       | 641.10              | 658.90  | 521.25 | Pass   |
| variation with samples without ageing | %                 | ± 25 max.   | + 0.42              | - 11.19 | - 8.07 |        |

### Outer Sheath (LLDPE)

| Item                                  | Unit              | Requirement | Measured/Determined | Result |
|---------------------------------------|-------------------|-------------|---------------------|--------|
| tensile strength                      | N/mm <sup>2</sup> | -----       | 19.20               | Pass   |
| variation with samples without ageing | %                 | -----       | - 2.98              |        |
| Elongation                            | %                 | ≥ 300       | 902.95              | Pass   |
| variation with samples without ageing | %                 | -----       | + 5.04              |        |



### 6.6 Pressure test at high temperature on non-metallic sheaths

#### Standard

IEC 60502-2 (2014) clause 19.9

#### Characteristic test data (Outer Sheath) LLDPE

- Oven Temperature 110°C ± 2K
- Time under load 6h
- Load 1926 grams

Calculated as per the specified test method

| Item                 | Unit | Requirement | Measured/Determined       | Result |
|----------------------|------|-------------|---------------------------|--------|
|                      |      |             | Median value of 3 samples |        |
| Depth of indentation | %    | ≤ 50        | 8.29 %                    | Pass   |

### 6.7 Hot set test for XLPE insulation

#### Standard

Standard IEC 60502-2(2014), clause 19.13

#### Characteristic test data

- Temperature 200 °C ± 3K
- Time under load 15 min
- Mechanical stress 20 N/cm<sup>2</sup>

| Item                  | Unit | Requirement | Measured/Determined |        |       | Result |
|-----------------------|------|-------------|---------------------|--------|-------|--------|
|                       |      |             | Red                 | Yellow | Blue  |        |
| Elongation under load | %    | ≤175        | 60.73               | 67.59  | 62.88 | Pass   |
| Permanent elongation  | %    | ≤15         | 2.94                | 0.64   | 2.28  | Pass   |

### 6.8 Water absorption test on insulation

#### Standard

Standard IEC 60502-2(2014), clause 19.15

#### Characteristic test data

- Temperature 85 °C ± 2K
- Duration 14 days

| Item              | Unit               | Requirement | Measured/Determined |        |       | Result |
|-------------------|--------------------|-------------|---------------------|--------|-------|--------|
|                   |                    |             | Red                 | Yellow | Blue  |        |
| Variation of mass | mg/cm <sup>2</sup> | ≤ 1         | 0.012               | 0.018  | 0.018 | Pass   |

### 6.9 Shrinkage test for XLPE insulation

#### Standard

Standard IEC 60502-2(2014), clause 19.18

#### Characteristic test data

Temperature 130 °C ± 3K  
Duration 1 h

| Item      | Unit | Requirement | Measured/Determined |        |      | Result |
|-----------|------|-------------|---------------------|--------|------|--------|
|           |      |             | Red                 | Yellow | Blue |        |
| Shrinkage | %    | ≤ 4         | 0.85                | 1.16   | 1.17 | Pass   |

### 6.10 Shrinkage test for LLDPE Sheath

#### Standard

Standard IEC 60502-2(2014), clause 19.22

#### Characteristic test data

Temperature 80 °C ± 2K  
Duration 5 Hrs , 5 Cycles

| Item      | Unit | Requirement | Measured/Determined | Result |
|-----------|------|-------------|---------------------|--------|
| Shrinkage | %    | ≤ 3         | 1.3                 | Pass   |

### 6.11 Strippability test for insulation screen before and after ageing

#### Standard

Standard IEC 60502-2(2014), clause 19.23

#### Characteristic test data

- Grip to grip separation speed 250 mm/min  
- Strip width 10 mm

#### Before ageing

| Item                | Unit | Requirement | Measured/Determined (Max.) |                    | Result |
|---------------------|------|-------------|----------------------------|--------------------|--------|
|                     |      |             | Mean ( all cores)          | Range ( all cores) |        |
| Strippability force | N    | 4 ≤ N ≤ 45  | 22.47                      | 12.45 ~ 31.02      | Pass   |

#### After ageing

| Item                | Unit | Requirement | Measured/Determined (Max.) |                    | Result |
|---------------------|------|-------------|----------------------------|--------------------|--------|
|                     |      |             | Mean ( all cores)          | Range ( all cores) |        |
| Strippability force | N    | 4 ≤ N ≤ 45  | 11.12                      | 6.10 ~ 17.50       | Pass   |



### 6.12 Carbon black contents (Outer LLDPE sheath)

#### Standard

Standard IEC 60502-2(2014), clause 19.17

#### Characteristic test data

- Purging gas 850 ~ 950 °C
- End temperature 950 °C

| Item                 | Unit | Requirement  | Measured/Determined (Max.) | Result |
|----------------------|------|--------------|----------------------------|--------|
| Carbon black content | %    | Min/Max: 2/3 | 2.717                      | Pass   |

- This test was conducted at Riyadh Cables test lab under KSU witness

## 7 VERIFICATION OF CABLE CONSTRUCTION

Verification of cable construction was carried out in accordance with clauses 5 to 14 of IEC 60502-2. (2014)  
The results are presented below.

|                                  | Measured / Determined  |
|----------------------------------|--|
| Marking of the cable             | <p><b>Arabic Embossing:</b></p> <p>٣ × ٣٥/٥٠٠ مم ٢ المنيوم/اكس ال بي اي / ال ال دي بي اي، ١٥ ك ف ، الوطنية لصناعة الكابلات ، الامارات العربية المتحدة، ٢٠١٩ ، املاك الشركة السعودية للكهرباء.</p> <p><b>English Embossing:</b></p> <p><b>3X500/35 MM2, AL/XLPE/LLDPE, 15kV NATIONAL CABLES INDUSTRIES - UAE, 2019, PROPERTY OF SAUDI ELECTRICITY COMPANY</b></p> |
| Color of the cores               | Red, Yellow, Blue identification tape  |
| Color of the outer sheath        | Black with two red strips  |
| Construction                     | 3 x 500/35 mm <sup>2</sup> -conductor of Aluminum wires -RMC shaped – Conductor Screen - XLPE Insulation - Strippable Type Insulation Screen - Copper Wires Metallic Screen - Open Helix Copper Tape Binder - Polypropylene Filler - Binder Tape- LLDPE – ST7 Outer Sheath   |
| Outer diameter of the cable (mm) | 96.77mm approx. (average)  |

**Note:** See also the manufacturer's drawing in **appendix A**.



8 Appendix A. Manufacturer's drawing / data sheet



**DIMENSIONS:**

| No. | DETAILS   |   |
|-----|---|---|
|     | Conductor Cross Section, mm <sup>2</sup>                      | 500   |
| 1   | Conductor (Circular stranded compacted)                       | Aluminium   |
| 2   | Conductor screen (Extruded semi-conductive compound)          | 0.51 (Min.)   |
| 3   | Nominal thickness of XLPE insulation, mm                      | 4.5   |
| 4   | Insulation screen (Extruded semi-conductive compound)         | 1.02 (Min.)   |
| 5   | Plain Annealed Copper Wires + Copper Binder Tape (open helix) | 27 x 0.7 (No. of wires x diameter)<br>15 x 0.1 (Open helix width x thickness) |
| 6   | Filler (Assembling)   | Polypropylene String  |
| 7   | Nominal thickness of binder tape, mm                          | 0.075   |
| 8   | Nominal thickness of LLDPE outer sheath, mm                   | 3.9   |
| A1  | Approximate diameter over conductor, mm                       | 26.7  |
| A2  | Approximate diameter over conductor screen, mm                | 28.3  |
| A3  | Approximate diameter over insulation, mm                      | 37.3  |
| A4  | Approximate diameter over insulation screen, mm               | 39.3  |
| A5  | Approximate diameter over metallic screen, mm                 | 41.9  |
| A6  | Approximate diameter over assembling, mm                      | 90.6  |
| A7  | Approximate diameter over binder tape, mm                     | 90.9  |
| A8  | Approximate diameter over outer sheath, mm                    | 99  |



P.O.Box: 27472 Sharjah, U.A.E. Tel: 06-5311888 Fax: 06-5311577  
E-mail: n\_c\_j@emirates.net.ae Website: www.nci.ae





# شهادة اعتماد

## ACCREDITATION CERTIFICATE



اللجنة السعودية للاعتماد  
Saudi Accreditation Committee

تشهد اللجنة السعودية للاعتماد (سالك) بأن  
Saudi Accreditation Committee (SAC) Declare that

High Voltage King Saud University Laboratory

Address: Riyadh

Scope : Electrical and electronic

مختبر الجهد العالي بجامعة الملك سعود

العنوان: الرياض

المجال : الكهربائية والإلكترونية

وذلك **17025** في المجال الملحق، بهذه الشهادة

في المجال الملحق، بهذه الشهادة

Has met the Requirements of Saudi Accreditation Committee (SAC) and has been accredited in compliance with SASO/ISO/IEC **17025** for the scope attached with this Certificate

رئيس اللجنة  
SAC,Chairman

سعد بن عثمان القسبي  
Saad O. Alkasabi



12/06/1441 : تاريخ الانتهاء / Expire Date

13/06/1438: تاريخ الاصدار / Issue Date

N-T-00017