

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Object 4-core power cable **1334-16**

Type AL/XLPE/PVC

Rated voltage, $U_0/U (U_m)$	0,6/1 (1,2) kV	Conductor material	AL
Conductor cross-section	4x300 mm ²	Insulation material	XLPE

Manufacturer National Cables Industry,
Sharjah, United Arab Emirates *)

Client National Cables Industry,
Sharjah, United Arab Emirates

Tested by KEMA Nederland B.V.,
Arnhem, the Netherlands

Date of tests 2 June to 8 July 2016

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with the complete type test requirements of

IEC 60502-1 (2009) subclauses 17 and 18

This Certificate has been issued by DNV GL following exclusively the STL Guides.

The results are shown in the record of proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as listed on page 5

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

*) as declared by the manufacturer

This Certificate consists of 27 pages in total.

KEMA Nederland B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories



Laboratories

Arnhem, 24 August 2016

INFORMATION SHEET

1 KEMA Type Test Certificate

A KEMA Type Test Certificate contains a record of a series of (type) tests carried out in accordance with a recognized standard. The equipment tested has fulfilled the requirements of this standard and the relevant ratings assigned by the manufacturer are endorsed by DNV GL. In addition, the test object's technical drawings have been verified and the condition of the test object after the tests is assessed and recorded. The Certificate contains the essential drawings and a description of the equipment tested. A KEMA Type Test Certificate signifies that the object meets all the requirements of the named subclauses of the standard. It can be identified by gold-embossed lettering on the cover and a gold seal on its front sheet.

The Certificate is applicable to the equipment tested only. DNV GL is responsible for the validity and the contents of the Certificate. The responsibility for conformity of any object having the same type references as the one tested rests with the manufacturer.

Detailed rules on types of certification are given in DNV GL's Certification procedure applicable to KEMA Laboratories.

2 KEMA Report of Performance

A KEMA Report of Performance is issued when an object has successfully completed and passed a subset (but not all) of test programmes in accordance with a recognized standard. In addition, the test object's technical drawings have been verified and the condition of the test object after the tests is assessed and recorded. The report is applicable to the equipment tested only. A KEMA Report of Performance signifies that the object meets the requirements of the named subclauses of the standard. It can be identified by silver-embossed lettering on the cover and a silver seal on its front sheet.

The sentence on the front page of a KEMA Report of Performance will state that the tests have been carried out in accordance with The object has complied with the relevant requirements.

3 KEMA Test Report

A KEMA Test Report is issued in all other cases. Reasons for issuing a KEMA Test Report could be:

- Tests were performed according to the client's instructions.
- Tests were performed only partially according to the standard.
- No technical drawings were submitted for verification and/or no assessment of the condition of the test object after the tests was performed.
- The object failed one or more of the performed tests.

The KEMA Test Report can be identified by the grey-embossed lettering on the cover and grey seal on its front sheet.

In case the number of tests, the test procedure and the test parameters are based on a recognized standard and related to the ratings assigned by the manufacturer, the following sentence will appear on the front sheet. The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on If the object does not pass the tests such behaviour will be mentioned on the front sheet. Verification of the drawings (if submitted) and assessment of the condition after the tests is only done on client's request.

When the tests, test procedure and/or test parameters are not in accordance with a recognized standard, the front sheet will state the tests have been carried out in accordance with client's instructions.

4 Official and uncontrolled test documents

The official test documents of DNV GL are issued in bound form. Uncontrolled copies may be provided as loose sheets or as a digital file for convenience of reproduction by the client. The copyright has to be respected at all times.

TABLE OF CONTENTS

1	Identification of the test object	5
1.1	Ratings/characteristics of the object tested	5
1.2	Description of the test object	5
1.3	List of documents	7
2	General information.....	8
2.1	The tests were witnessed by	8
2.2	The tests were carried out by	8
2.3	Subcontracting	8
2.4	Purpose of test	8
2.5	Measurement uncertainty	8
3	Conductor	9
3.1	Measurement of the resistance of the conductor	9
3.2	Measurement of the number of wires of the conductor	9
3.3	Measurement of the dimensions of the conductor	9
4	Electrical type tests	10
4.1	Measurement of insulation resistance at ambient temperature	10
4.2	Measurement of insulation resistance at max. conductor temperature	11
4.3	Voltage test for 4 h	12
5	Non-electrical type tests	13
5.1	Measurement of thickness of insulation	13
5.2	Measurement of thickness of non-metallic sheaths	13
5.3	Tests for determining the mechanical properties of insulation before and after ageing	14
5.4	Tests for determining the mechanical properties of non-metallic sheaths before and after ageing	15
5.5	Additional ageing test on pieces of completed cables	16
5.6	Loss of mass test on PVC sheaths of type ST ₂	17
5.7	Pressure test at high temperature on non-metallic sheaths	18
5.8	Test on PVC insulation and sheaths and halogen free sheaths at low temperatures	19
5.9	Test for resistance of PVC insulation and sheaths to cracking (heat shock test)	20
5.10	Hot set test for XLPE insulation	21
5.11	Water absorption test on insulation	22
5.12	Fire tests	23
5.12.1	Flame spread test on single cables	23
5.13	Shrinkage test for XLPE insulation	24



KEMA Laboratories	-4-	1334-16
6	Verification of cable construction	25
7	Drawing	26
8	Measurement uncertainties.....	27

1 IDENTIFICATION OF THE TEST OBJECT

1.1 Ratings/characteristics of the object tested

Rated voltage, U_0/U (U_m)	0,6/1 (1,2) kV
Rated maximum conductor temperature in normal operation	90 °C
Rated conductor cross-section	300 mm ²

1.2 Description of the test object

Manufacturer	National Cables Industry, Sharjah, United Arab Emirates
Type	4x300mm ² AL/XLPE/PVC
Manufacturing year	2016
Standard	IEC 60502-1 SEC specs No. 11-SDMS-01, Rev.02
Sampling procedure	by the manufacturer
Rated voltage, U_0/U	0,6/1 KV
No. of cores	4
Marking on the cable	NATIONAL CABLES INDUSTRY U.A.E 2016 4x300, MM2 AL/XLPE/PVC 0.6/1 KV PROPERTY OF SAUDI ELECTRICITY COMPANY

Conductor

• material	aluminium
• cross-section	300 mm ²
• nominal dimensions	27,5 x 19,6 mm
• type	sector shaped
• maximum conductor temperature in normal operation	90 °C

Insulation

• material	XLPE
• nominal thickness	1,8 mm
• material designation	GP 8
• material supplier	Riyadh Cables and Metals
• core identification	red / yellow / blue / black

Fillers and binders

yes

Binder tape

• material	polypropylene tape
• dimensions	60 x 0,10 mm

Oversheath

- material PVC, type ST₂
- nominal thickness 3,0 mm
- outer diameter of cable 61 mm
- material designation PVC ST₂ / Type 9 (RCS 90) Sheath
- material supplier Riyadh Cables and Metals
- colour black

Manufacturing details insulation system

- location of manufacturing Sharjah, United Arab Emirates
- factory identification of extrusion line National Cables Industry, United Arab Emirates
- manufacturer of the extrusion line Nextrom LP – 150
- identification of the production batch 51312918
- manufacturing length (where cable sample for testing has been taken from) 500 m
- length markings on cable sample sent to KEMA Laboratories begin: 42 m, end: 92 m

1.3 List of documents

On request of the manufacturer the following drawings and/or documents have been included in this report.

KEMA Laboratories has not verified these drawings and/or documents.

Drawing no./document no.

Revision

Drawing 0,6/1 kV, 4 cores, XLPE INSULATED, PVC
SHEATHED AL/XLPE/PVC POWER CABLE

-

2 GENERAL INFORMATION

2.1 The tests were witnessed by

The tests were carried out without a representative of the client present.

2.2 The tests were carried out by

Name	Company
E.F. Rijpstra	KEMA Nederland B.V.,
F.B. Rasing	Arnhem, the Netherlands

2.3 Subcontracting

All tests were subcontracted to DNV GL – New Energy Technology, Arnhem, the Netherlands.

2.4 Purpose of test

Purpose of the test was to verify whether the material complies with the specified requirements.

2.5 Measurement uncertainty

A table with measurement uncertainties is enclosed in this Certificate. Unless otherwise stated, the measurement uncertainties of the results presented in this Certificate are as indicated in that table.

3 CONDUCTOR

Standard and date

Standard IEC 60502-1 clause 5
 Test date 2 June 2016

3.1 Measurement of the resistance of the conductor

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Resistance	Ω/km	$\leq 0,100$	0,097	0,097	0,097	0,097

Result

The object passed the test.

3.2 Measurement of the number of wires of the conductor

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Number of wires	-	≥ 30	37	37	37	37

Result

The object passed the test.

3.3 Measurement of the dimensions of the conductor

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Dimensions	mm	-	26,42 x 19,58	26,58 x 19,55	26,23 x 19,99	26,37 x 19,25

Result

The result is for information only.

4 ELECTRICAL TYPE TESTS

4.1 Measurement of insulation resistance at ambient temperature

Standard and date

Standard IEC 60502-1, clause 17.1

Test date 2 June 2016

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Volume resistivity, ρ						
at 20 °C	$\Omega \cdot \text{cm}$	-	$3,55 \cdot 10^{13} *$	$4,44 \cdot 10^{13} *$	$3,71 \cdot 10^{13} *$	$3,63 \cdot 10^{13} *$
Insulation resistance constant, K_i						
at 20 °C	$M\Omega \cdot \text{km}$	-	130	163	136	133

Result

The test results are for information only.

4.2 Measurement of insulation resistance at max. conductor temperature

Standard and date

Standard IEC 60502-1, clause 17.2

Test date 3 June 2016

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Volume resistivity, ρ						
at 90 °C	$\Omega \cdot \text{cm}$	$\geq 10^{12}$	2,16 * 10^{13}	2,02 * 10^{13}	2,23 * 10^{13}	2,16 * 10^{13}
Insulation resistance constant, K_i						
at 90 °C	M $\Omega \cdot \text{km}$	$\geq 3,67$	79	74	82	79

Result

The object passed the test.

4.3 Voltage test for 4 h

Standard and date

Standard IEC 60502-1, clause 17.3

Test date 6 June 2016

Environmental conditionsTemperature 20 ± 15 °C

Temperature of test object 22 °C

Applied voltage (kV)	Frequency (Hz)	Duration (h)	Measured/determined
2,4	50	4	No breakdown

Requirement

No breakdown of the insulation shall occur.

Result

The object passed the test.

5 NON-ELECTRICAL TYPE TESTS

5.1 Measurement of thickness of insulation

Standard and date

Standard IEC 60502-1, clause 18.1

Test date 10 June 2016

Thickness	Unit	Requirement	Specified	Measured/determined			
				Red	Yellow	Blue	Black
Nominal	mm	1,8	1,8	-	-	-	-
Average	mm	-	-	2,65	2,86	2,77	2,65
Minimum (t_m)	mm	$\geq 1,52$	-	2,27	2,21	2,15	2,27

Result

The object passed the test.

5.2 Measurement of thickness of non-metallic sheaths

Standard and date

Standard IEC 60502-1, clause 18.2

Test date 10 June 2016

Oversheath

Thickness	Unit	Requirement	Specified	Measured/determined
Nominal	mm	-	3,0	-
Average	mm	-	-	2,97
Minimum (t_m)	mm	$\geq 2,20$	-	2,75

Note

The nominal thickness of the oversheath is specified by customer according to clause 12.3.3 and Annex A of IEC 60502-1.

Result

The object passed the test.

5.3 Tests for determining the mechanical properties of insulation before and after ageing

Standard and date

Standard IEC 60502-1, clause 18.3

Test dates 20 June to 7 July 2016

Characteristic test data

Temperature during ageing 135 ± 3 °C

Duration 7 days

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Without ageing						
Tensile strength	N/mm ²	≥ 12,5	27,3	26,8	27,9	24,0
Elongation	%	≥ 200	632	662	659	642
After ageing						
Tensile strength	N/mm ²	-	26,8	24,2	28,5	29,4
Variation with samples without ageing	%	± 25 max.	-2	-10	2	22
Elongation	%	-	634	584	642	627
Variation with samples without ageing	%	± 25 max.	0	-12	-3	-2

Result

The object passed the test.

5.4 Tests for determining the mechanical properties of non-metallic sheaths before and after ageing

Standard and date

Standard IEC 60502-1, clause 18.4
 Test date 20 June to 8 July 2016

Characteristic test data

Temperature during ageing 100 ± 2 °C
 Duration 7 days

Oversheath

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm ²	≥ 12,5	20,2
Elongation	%	≥ 150	244
After ageing			
Tensile strength	N/mm ²	≥ 12,5	18,1
Variation with samples without ageing	%	± 25 max.	-7
Elongation	%	≥ 150	214
Variation with samples without ageing	%	± 25 max.	-13

Result

The object passed the test.

5.5 Additional ageing test on pieces of completed cables

Standard and date

Standard IEC 60502-1, clause 18.5

Test dates 10 June to 8 July 2016

Characteristic test data

Temperature during ageing 100 ± 2 °C

Duration 7 days

Insulation

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Tensile strength	N/mm ²	-	26,5	25,7	26,4	25,8
Variation with samples without ageing	%	± 25 max.	-3	-4	-5	8
Elongation	%	-	588	561	615	598
Variation with samples without ageing	%	± 25 max.	-7	-15	-7	-7

Oversheath

Item	Unit	Requirement	Measured/determined			
Tensile strength	N/mm ²	-	20,0			
Variation with samples without ageing	%	± 25 max.	-1			
Elongation	%	-	259			
Variation with samples without ageing	%	± 25 max.	6			

Result

The object passed the test.

5.6 Loss of mass test on PVC sheaths of type ST₂

Standard and date

Standard IEC 60502-1, clause 18.6

Test dates 14 June to 7 July 2016

Characteristic test data

Temperature during ageing 100 ± 2 °C

Duration 7 days

Oversheath

Item	Unit	Requirement	Measured/Determined
Loss of mass	mg/cm ²	≤ 1,5	0,48

Result

The object passed the test.

5.7 Pressure test at high temperature on non-metallic sheaths

Standard and date

Standard IEC 60502-1, clause 18.7
Test date 3 June 2016

Characteristic test data

Temperature during ageing 90 ± 2 °C
Duration 6 h
Load 13 N

Oversheath

Item	Unit	Requirement	Measured/Determined
Depth of indentation	%	≤ 50	18

Result

The object passed the test.

5.8 Test on PVC insulation and sheaths and halogen free sheaths at low temperatures

Standard and date

Standard IEC 60502-1, clause 18.8
Test dates 3 to 14 June 2016

Characteristic test data

Temperature -15 ± 2 °C
Period of application 16 h
Mass of hammer 1250 g

Oversheath

Item	Unit	Requirement	Measured/Determined
Cold elongation	%	≥ 20	73
Cold impact test	-	no cracks	no cracks

Result

The object passed the test.

5.9 Test for resistance of PVC insulation and sheaths to cracking (heat shock test)

Standard and date

Standard IEC 60502-1, clause 18.9
Test date 3 June 2016

Characteristic test data

Temperature 150 ± 3 °C
Period of application 1 h
Diameter of mandrel 6 mm
Number of turns 6

Oversheath

Item	Unit	Requirement	Measured/Determined
Soundness	-	no cracks	no cracks

Result

The object passed the test.

5.10 Hot set test for XLPE insulation

Standard and date

Standard IEC 60502-1, clause 18.11

Test date 28 June 2016

Characteristic test data

Temperature 200 ± 3 °C

Time under load 15 min

Mechanical stress 20 N/cm²

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Elongation under load	%	≤ 175	68	65	70	58
Permanent elongation	%	≤ 15	-5	0	0	-3

Result

The object passed the test.

5.11 Water absorption test on insulation

Standard and date

Standard IEC 60502-1, clause 18.13

Test dates 7 to 27 June 2016

Characteristic test data

Temperature 85 ± 2 °C

Duration 14 days

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Variation of mass	mg/cm ²	≤ 1	0,04	0,02	0,03	0,02

Result

The object passed the test.

5.12 Fire tests

5.12.1 Flame spread test on single cables

Standard and date

Standard IEC 60502-1, clause 18.14.1

Test date 15 June 2016

Characteristic test data

Duration 240 s

Item	Unit	Requirement	Measured/determined
Length free of charring	mm	> 50	352
Downward limit charred surface	mm	< 540	494

Result

The object passed the test.

5.13 Shrinkage test for XLPE insulation

Standard and date

Standard IEC 60502-1, clause 18.16

Test date 3 June 2016

Characteristic test data

Temperature 130 ± 3 °C

Duration 1 h

Item	Unit	Requirement	Measured/determined			
			Red	Yellow	Blue	Black
Shrinkage	%	≤ 4	1,7	2,4	2,2	1,7

Result

The object passed the test.

6 VERIFICATION OF CABLE CONSTRUCTION

Verification of cable construction was carried out in accordance with clauses 5-13 of IEC 60502-1. The results are presented below.

	Observed/determined
Marking on the cable	NATIONAL CABLES INDUSTRY U.A.E 2016 4x300, MM2 AL/XLPE/PVC 0.6/1 KV PROPERTY OF SAUDI ELECTRICITY COMPANY
Construction	Aluminium Conductor
	XLPE Insulation
	Filler
	Binding tape
	PVC Oversheath
Outer diameter of the cable, average	61 mm
Outer diameter of the cores, average	Red: 31,70 x 25,25 mm Yellow: 31,46 x 24,74 mm Blue: 31,23 x 24,79 mm Black: 31,21 x 24,64 mm

Result

No significant deviations from the specified requirements are found.

7 DRAWING


TECHNICAL & QC
DEPARTMENT

الوطنية لصناعة الكابلات
NATIONAL CABLES INDUSTRY NCI

DRAWING

**0.6/1 kV, 4 CORES, XLPE INSULATED, PVC SHEATHED
AL/XLPE/PVC POWER CABLE**

Applicable Standard : SEC Specs No. 11-SDMS-01, Rev.02 and as per IEC 60502-1



Size: 4x300 mm², AL/XLPE/PVC - 0.6/1 kV

- | | |
|--------------------|--|
| 1. Conductor | : Aluminium, Sectoral Stranded Compacted |
| 2. Insulation | : Extruded Cross Linked Polyethylene (XLPE) |
| Nominal thickness: | : 1.8 mm |
| | Color: Red, Yellow, Blue, Black |
| 3. Fillers | : Polypropylene Fillers |
| 4. Binding Tape | : Polypropylene Tape |
| 5. Outer Covering | : Extruded Polyvinyl Chloride (PVC), Colour: BLACK |
| Nominal thickness: | : 3.0 mm |

Embossing on the Outer Sheath in Max. 100 cm Spacing (English & Arabic) :

**NATIONAL CABLES INDUSTRY, U.A.E., 2016, 4x300 mm², AL/XLPE/PVC, 0.6/1 kV
PROPERTY OF SAUDI ELECTRICITY COMPANY**

P.O. Box: 27472 Sharjah, U.A.E. ☎ Tel: 06-5311888 📠 Fax: 06-5311577

E-mail: n_c_j@emirates.net.ae Website: www.nci.ae



8 MEASUREMENT UNCERTAINTIES

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

Measurement	Measurement uncertainty
Tensile strength test	1%
Measurement of dimensions	5 μm
Measurement loss of mass	0,11 mg : 8,0 gr
Measurement of conductor resistance	0,03% of measured value
Measurement at low temperature	0,1 $^{\circ}\text{C}$
Measurement in heating cabinets	0,1 $^{\circ}\text{C}$
Voltage test	$2 \cdot 10^{-3} \cdot u + 20\text{v}$ $2 \cdot 10^{-3} \cdot i + 0,2\%$